

JANUARY 1938

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM
NONE INCLUDED

Explanation

Instruments all standard La Coeur
All charts complete Greenwich days except for charts showing only part days.
Parallax correction to be added to times as read from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
Temperature Trace
H Trace
1 Baseline
(Temperature trace reflection)
2 Baseline
D Trace
3 Baseline and Trace.
Effective temperature coefficient:
1 Baseline values increase with increasing temperature.
2 Algebraic Baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
D Trace
D Baseline (up or line where double)
1 Baseline
D Trace
H Trace
2 Trace
3 Trace
4 Baseline

Clock correct to within 30 seconds throughout

Temperature trace
Scale Value
Base Line
Parallax correction

0.527°C/mm
-31.5°C
+ 4 minutes

Horizontal force trace
Scale Value
Base Line

4.43 Y/mm
23484Y at 0°C

16.1 Y/mm
Actual

Temperature coefficient
Parallax correction
Reflection distance:
Main trace to 1st refl. down

4.50 Y/°C
+ 2 minutes
89.6mm

—
Nil

Declination trace
Scale Value
Base Line Actual

0.92 minutes arc/mm
17°39.6'

2.36 minutes arc/mm

Parallax correction
Reflection distance:
Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace
Scale Value
Base Line

2.50Y/mm
-36995 at 0°C

10.9 Y/mm
Actual

Temperature coefficient
Parallax correction
Reflection distance:
Main trace to 1st refl. down

2.96 Y/°C
Nil
95.6mm

—
- 2 minutes

Distance between base lines

H to Z 155.9mm

D to Z

Extreme values , daily ranges , and K-indices.

January 1956.

U.T.	h.m.	H			D			Z			K - indices.	C figure	Mean daily temp. of variometer room.								
		Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(36000+)	Minimum. -(36000+)	Range.											
Date.											E 1 2 3 4 5 6 7 8 Sum.		C								
1	D	01 45	617	446	14 38	171	19 09	28.0	02.9	07 46	25.1	05 48	898	1058	21 08	140	5 5 5 4	4 5 4 4	54	2	+6.5
2		00 57	605	505	11 58	100	18 19	24.0	05.7	07 52	20.3	11 59	912	1040	00 07	128	4 4 5 5	4 2 5 5	28	1	+7.5
3	Q	19 04	604	525	14 37	79	17 46	21.4	04.5	09 34	16.9	13 20	914	982	00 09	63	2 2 1 1	1 1 2 2	12	0	+7.7
4	Q	23 49	636	525	13 32	111	17 00	21.8	04.7	10 02	17.1	14 42	900	976	23 49	76	1 1 1 1	1 1 1 4	11	0	+7.8
5	Q	19 33	634	535	13 52	99	17 17	20.9	03.5	10 52	17.4	15 51	901	969	00 01	68	3 2 2 2	2 2 2 5	18	1	+7.2
6		19 11	635	542	13 52	95	17 41	21.7	02.0	08 52	19.7	12 16	904	962	18 58	58	2 2 3 3	3 3 3 3	22	1	+6.5
7	Q	19 05	641	545	13 39	96	16 56	20.4	02.6	10 16	17.8	13 51	898	961	21 21	65	3 3 2 2	3 1 3 3	20	1	+6.5
8	Q	22 55	624	535	12 58	91	17 29	21.4	59.7 ⁺	09 27	21.7	13 16	889	953	22 57	67	2 2 2 2	2 1 1 2	14	0	+6.3
9		23 44	627	529	14 04	98	17 47	20.5	58.9 ⁺	10 33	21.6	13 38	885	983	21 49	98	1 1 2 2	3 3 3 3	16	1	+6.4
10		01 19	625	517	15 18	108	16 51	22.9	00.8	10 33	22.1	15 29	889	983	01 41	94	4 2 2 2	3 2 4 3	22	1	+6.3
11		02 05	640	528	14 40	112	17 51	23.9	03.3	10 11	20.6	15 39	889	975	00 22	84	3 3 3 3	2 3 5 4	26	1	+6.4
12		02 13	634	518	14 41	116	19 06	20.4	03.3	10 12	17.1	15 44	884	977	22 40	95	3 3 3 3	3 3 3 4	25	1	+6.5
13		04 34	641	532	16 22	109	20 17	19.3	03.7	10 59	15.6	16 23	900	986	21 29	88	3 3 3 2	2 2 4 4	23	1	+6.4
14		20 37	624	512	15 33	112	16 48	24.4	04.6	11 31	19.8	12 45	899	983	20 42	84	3 1 2 3	3 3 4 4	23	1	+6.5
15		21 35	629	511	17 19	118	19 34	19.5	00.9	07 54	16.6	16 48	890	985	21 37	95	3 3 4 3	4 4 4 4	29	2	+6.5
16		05 46	634	553	15 36	81	18 52	18.4	05.6	10 09	12.8	15 15	894	980	21 31	83	2 3 3 3	3 3 4 5	26	1	+6.5
17	D	20 31	623	525	15 02	96	17 35	19.8	05.7	08 20	14.1	14 36	884	997	22 30	113	3 3 3 4	4 4 4 4	29	2	+6.6
18	D	07 35	610	527	13 52	83	17 34	22.1	02.3	09 40	19.8	09 50	887	991	00 20	104	4 4 5 4	4 3 4 2	30	2	+6.5
19		21 42	610	526	14 31	84	17 16	20.4	05.6	10 07	14.8	13 22	899	971	01 17	72	3 2 2 2	2 3 3 4	21	1	+6.4
20		22 27	651	525	15 22	126	18 09	20.6	05.3	09 42	15.3	14 49	897	1005	22 27	108	3 3 3 4	3 3 4 5	28	2	+6.5
21	D	- -	-	-	-	-	- -	-	-	- -	-	- -	-	-	- -	-	3 5 - -	- - - 3	11+	2	+6.5
22		02 43	614	494	13 32	120	18 26	21.8	01.0	11 13	20.6	13 00	888	974	23 26	86	3 3 3 5	4 3 4 4	29	2	+6.6
23	D	00 54	619	506	15 35	111	18 26	22.1	03.7	10 31	18.4	16 00	900	981	00 56	81	4 3 3 3	3 3 4 3	26	1	+6.5
24		04 59	603	506	15 39	97	18 58	19.8	05.8	11 00	14.0	15 41	904	962	22 39	58	1 2 2 3	4 2 2 2	18	1	+6.5
25		00 31	616	510	15 50	106	17 15	21.2	02.8	11 30	18.4	14 05	886	970	00 31	84	3 2 2 4	4 4 3 3	25	1	+6.9
26		02 25	620	519	16 36	101	17 31	19.5	01.9	05 30	17.6	07 00	902	976	23 50	76	3 4 4 3	2 3 3 3	25	1	+6.6
27		02 41	603	518	16 15	85	19 22	18.9	06.3	14 11	10.6	16 19	893	976	00 01	83	3 1 2 1	1 2 4 3	17	1	+6.6
28		09 55	607	532	17 42	75	19 17	18.5	04.2	11 15	14.3	14 33	902	951	23 37	49	2 1 2 3	2 3 3 2	16	1	+6.6
29		00 41	630	516	15 17	114	17 48	22.1	59.9 ⁺	07 10	22.2	15 47	883	964	00 46	81	3 3 4 3	2 3 3 1	22	1	+6.8
30		05 25	639	537	15 42	102	18 12	20.1	03.0	10 16	17.1	15 10	898	956	20 52	58	1 2 3 3	3 2 2 2	18	1	+6.9
31		23 22	622	521	16 12	101	19 44	19.7	04.8	13 48	14.9	16 35	896	961	23 23	65	2 2 2 2	2 2 3 3	16	1	+7.0

+ 16 00.0+ tabulated value

FEBRUARY 1958

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Coeur
 All charts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to times as read from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
 Temperature Trace
 H Trace
 Baseline
 (Temperature trace reflection)
 J Baseline
 J Trace
 J Baseline and Trace.
 Effective temperature coefficient:
 1. Baseline values increase with increasing temperature.
 2. Algebraic Baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
 D Trace
 D Baseline, "J" Baseline (where double)
 Baseline
 D Trace
 H Trace
 J Trace
 J Baseline

Clock correct to within 30 seconds throughout

Temperature trace
 Scale Value
 Base Line
 Parallax correction

0.527°C/mm
 -31.5°C
 + 4 minutes

Horizontal force trace
 Scale Value
 Base Line

4.43 Y/mm
 23484Y at 0°C

16.1 Y/mm
 24012Y Actual

Temperature coefficient
 Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

4.50 Y/°C
 + 2 minutes
 89.6mm

—
 Nil

Declination trace
 Scale Value
 Base Line Actual

0.92 minutes arc/mm
 17°39.6'

2.36 minutes arc/mm
 16°23.9'

Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace
 Scale Value
 Base Line

2.50Y/mm
 1st to 5th -36995Y at 0°C
 6th to 15th -36996Y " "
 16th to 27th -36997Y " "
 28th to 29th -36998Y " "

10.9 Y/mm
 -36819Y Actual

Temperature coefficient
 Parallax correction
 Reflection distances:
 Main trace to 1st refl. down.

2.96 Y/°C
 Nil
 95.6mm

—
 - 2 minutes

Distance between base lines

H to Z 155.8mm

D to Z 176.5mm

Extreme values , daily ranges , and K-indices.

February 1958.

U.T.	H			D			Z			K - indices.	C figure	Mean daily temp. of variometer room.							
	Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(36000+)	Minimum. -(36000+)	Range.										
Date.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	B 1 2 3 4 5 6 7 8 Sum.	C								
1	23 58	619	550 14 32	69	18 01	18.4	03.5	11 33	14.9	16 09	898	956	23 59	58	2 2 2 3	2 2 2 3	18	1	+7.0
2	00 45	629	554 15 05	95	17 57	18.1	02.7	11 25	15.4	14 19	901	966	00 48	35	3 3 2 3	3 2 2 2	20	1	+7.0
3	22 30	624	554 14 42	90	17 30	19.4	02.8	10 21	16.6	12 40	898	955	23 50	55	2 5 3 2	4 2 3 3	22	1	+6.9
4	18 30	645	518 15 25	127	18 51	23.5	02.6	10 42	20.7	15 01	871	963	23 18	92	3 2 2 3	4 5 5 4	28	1	+6.7
5	19 53	644	494 12 32	150	16 15	20.7	00.5	10 19	20.2	12 35	879	975	21 42	96	3 4 4 4	5 3 5 4	32	2	+6.6
6	04 22	655	472 15 44	161	17 18	27.0	06.0	10 40	21.0	14 49	898	995	23 10	97	4 4 4 4	3 4 3 4	30	2	+6.5
7	22 09	616	488 15 38	130	19 21	20.3	04.6	11 06	15.7	16 13	898	978	22 15	80	3 3 3 4	3 3 4 4	27	1	+6.4
8	03 35	619	469 14 34	150	17 30	22.9	03.9	11 33	19.0	14 31	879	988	23 10	107	3 4 3 4	4 4 4 4	30	2	+6.4
9	00 27	615	484 16 08	131	19 23	26.2	06.6	11 42	19.6	16 30	881	983	22 07	102	4 3 2 3	3 3 4 4	26	1	+6.7
10	01 01	611	492 17 03	119	19 20	26.9	05.5	12 01	21.4	16 14	881	1012	22 10	131	4 3 2 3	2 3 4 4	25	1	+7.0
11	02 34	1044	814 ⁺ 09 18	1230	09 39	51.7	21.6 ⁺⁺	02 32	150.1	06 46	252	1178	02 25	926	9 8 9 8	7 4 5 5	55	2	+6.8
12	21 23	623	440 18 02	183	18 50	27.9	05.7	10 20	22.2	07 24	886	1044	00 28	158	5 5 5 4	4 5 5 5	38	2	+6.8
13	00 43	584	491 15 39	93	18 26	24.9	07.9	12 14	17.0	15 44	902	979	00 43	77	3 2 2 3	4 2 2 3	21	1	+6.8
14	04 39	590	510 16 43	80	17 01	20.4	06.2	03 33	14.2	16 28	899	985	01 01	84	3 4 4 2	2 3 2 2	22	1	+6.8
15	24 00	598	513 16 23	85	18 27	19.6	06.7	13 29	12.9	16 26	901	981	01 03	60	2 1 2 2	2 3 3 3	18	1	+6.8
16	23 44	622	559 15 25	83	18 14	20.6	03.4	11 04	17.2	15 27	903	956	23 44	53	2 1 2 3	3 3 3 4	21	1	+6.7
17	01 09	678	501 18 46	177	18 18	21.3	05.6	10 11	15.7	13 32	904	981	01 10	77	5 4 4 4	4 4 4 3	32	2	+6.7
18	01 17	597	491 15 32	106	18 32	23.8	03.8	04 01	20.0	16 41	893	976	22 38	83	4 4 3 4	4 3 4 4	30	2	+6.7
19	23 32	608	493 16 34	115	18 08	22.1	05.3	00 33	16.8	16 37	903	979	23 32	76	4 3 3 3	3 3 4 4	27	1	+6.2
20	04 22	596	506 14 19	88	20 49	22.9	08.1	09 00	14.8	14 19	903	990	22 15	87	3 3 3 3	4 3 4 4	27	1	+6.3
21	03 13	612	507 14 00	105	18 26	27.7	05.4	07 18	22.3	05 47	902	998	22 20	96	3 4 4 3	4 3 4 4	29	2	+6.5
22	02 12	618	504 16 12	114	18 20	21.9	00.8	01 59	21.1	15 33	907	989	22 19	82	5 3 3 3	3 2 3 4	26	1	+6.4
23	01 29	611	482 15 37	129	18 04	21.3	05.5	03 00	15.8	15 07	906	988	21 01	80	4 4 3 3	3 3 3 3	26	1	+6.4
24	04 02	596	516 15 40	80	18 21	20.6	07.4	12 34	13.2	16 01	895	955	00 05	60	1 3 2 2	2 1 2 1	14	0	+6.6
25	03 25	601	509 16 33	92	19 02	21.1	06.2	06 52	14.9	16 38	903	955	21 44	52	1 2 3 2	1 1 2 2	14	0	+6.7
26	02 38	609	526 15 22	83	20 05	17.6	04.5	11 02	13.1	16 19	901	949	01 09	48	2 3 3 3	2 1 2 3	19	1	+6.6
27	01 59	606	528 16 01	80	20 12	21.2	03.4	12 32	17.6	16 06	900	949	23 39	49	3 2 1 2	2 2 4 3	19	1	+6.7
28	02 34	605	514 17 12	91	19 27	18.3	03.0	11 25	15.3	15 59	898	952	22 29	54	2 2 3 4	4 3 3 3	24	1	+6.6

+ 22000 + tabulated value.

++ 15 00.0+ tabulated value.

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Temperature trace
Scale Value
Base Line
Parallax correction

0.527°C/mm
-31.5°C
+ 4 minutes

Horizontal force trace
Scale Value
Base Line

4.43 Y/mm
1st to 15th 25484Y at 0°C
16th to 31st 25423Y " "

16.1 Y/mm

Actual

Temperature coefficient
Parallax correction
Reflection distance:
Main trace to 1st refl. down

4.50 Y/°C
+ 2 minutes
89.6mm

Nil

Declination trace
Scale Value
Base Line Actual

0.92 minutes arc/mm
17°39.6'

2.36 minutes arc/mm
1st to 17th 16°25.9'
19th to 31st 16°22.7'

Parallax correction
Reflection distance:
Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace
Scale Value
Base Line

2.50Y/mm
1st to 11th -36998Y at 0°C
12th to 31st -36999Y " "

10.9 Y/mm
-36320Y

Actual

Temperature coefficient
Parallax correction
Reflection distances:
Main trace to 1st refl. down

2.00 Y/°C
Nil
95.5mm

- 2 minutes

Distance between base lines

H to Z 155.8mm

D to Z 176.6mm

Explanation

Instruments all standard La Coeur
All charts complete Greenwich days except for charts showing only par. days.
Parallax correction to be a left to right as read from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
Temperature Trace
H Trace
Baseline
Temperature trace reflection,
Baseline
J Trace
Baseline and Trace.
Effective temperature coefficient:
1. Baseline values increase with increasing temperature.
2. Algebraic Baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
J Trace
Baseline, "Y" or line are double
Baseline
I Trace
H Trace
J Trace
Baseline

Block correct to within 30 seconds throughout

Extreme values , daily ranges , and K-indices.

March 1958.

U.T.	h.m.	H			D			Z			K - indices.									C figure	Mean daily temp. of variometer room.						
		Maximum. 23000+	Minimum. 23000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. (36000+)	Minimum. (36000+)	Range.	E	1	2	3	4	5	6	7	8			Sum.					
Date.																											
1	Q	04 25	598	500	16 55	96	19 42	20.7	05.7	13 09	15.0	16 34	884	948	23 50	64	2	2	1	2	1	2	2	2	14	0	+6.6
2	Q	04 48	599	517	15 49	82	18 48	18.3	05.6	08 41	12.7	15 52	891	949	00 02	58	1	3	3	2	2	0	1	1	13	0	+7.0
3		19 08	621	515	16 11	103	19 12	26.6	01.9	10 41	24.7	15 40	895	972	21 44	79	2	3	2	3	3	3	5	4	25	1	+6.9
4		03 46	600	512	17 09	88	18 41	21.2	58.8+	02 47	22.4	02 53	905	979	22 29	74	5	4	4	3	3	3	3	4	29	1	+7.2
5	D	08 12	628	462	16 14	168	17 22	21.7	58.7+	05 59	23.0	07 29	740	979	22 32	239	3	4	6	5	4	3	3	4	32	2	+7.3
6		02 04	622	465	15 52	157	18 59	22.5	00.5	02 00	22.0	16 01	903	969	22 07	66	5	4	3	3	4	3	3	4	29	2	+7.3
7		02 40	588	471	16 44	117	19 39	23.1	03.1	04 58	20.0	16 46	891	966	23 02	75	3	4	4	3	3	3	3	3	26	1	+7.3
8		06 36	577	482	14 34	95	19 11	21.0	06.8	13 11	14.2	17 29	911	970	23 16	59	3	3	4	3	3	2	2	3	23	1	+7.4
9		05 33	588	489	16 00	99	19 13	21.7	02.3	01 33	19.4	16 01	897	964	21 15	67	5	3	3	3	3	2	2	2	23	1	+7.2
10		11 02	602	494	18 00	108	18 27	23.6	05.7	04 22	17.9	16 56	900	969	23 40	69	3	4	3	3	2	3	3	3	24	1	+7.3
11		10 52	593	493	16 57	100	19 42	24.0	0.30	11 45	21.0	16 40	888	983	23 59	95	4	1	1	3	2	3	3	4	21	1	+7.2
12	D	23 48	573	470	05 34	103	18 11	22.5	58.3+	03 01	24.2	07 23	817	990	01 09	173	6	5	5	5	3	4	3	3	34	2	+7.3
13	D	10 07	596	440	15 45	156	18 32	24.0	59.3+	06 43	24.7	07 59	852	976	22 28	124	3	4	4	5	5	4	4	3	32	2	+7.5
14		23 36	590	472	16 01	118	19 32	19.8	55.8+	12 12	23.0	15 58	886	970	00 01	84	3	2	1	2	5	3	3	3	22	1	+7.3
15		03 02	627	472	16 12	155	17 41	21.0	03.9	06 10	17.1	16 12	904	962	20 50	58	4	5	4	4	3	3	3	2	28	1	+7.4
16	Q	08 42	576	463	15 51	93	18 21	19.1	03.6	02 02	15.5	03 50	910	962	00 51	52	4	4	3	3	2	2	2	3	25	1	+7.1
17		08 19	611	494	19 54	117	19 36	23.0	02.9	09 51	20.1	09 50	862	955	00 42	93	3	3	5	5	3	3	4	3	29	2	+7.0
18		02 18	590	473	16 04	117	20 21	24.8	05.5	03 12	19.3	07 20	879	970	21 31	91	4	4	4	3	4	4	4	4	31	2	+6.8
19	D	08 22	592	479	16 36	113	20 11	24.0	03.1	03 39	20.9	06 38	892	998	23 07	106	5	5	4	3	4	4	4	5	34	2	+6.7
20	D	12 00	587	467	17 14	100	19 17	22.8	06.0	03 51	16.8	16 12	910	978	00 07	68	4	4	3	3	3	2	4	5	28	1	+6.6
21		10 38	580	462	16 12	118	18 33	23.6	03.7	00 19	19.9	16 09	895	980	22 32	85	4	4	3	3	4	3	3	3	27	1	+7.0
22		00 29	586	477	15 11	109	16 43	20.2	59.0+	03 09	21.2	16 30	915	937	22 31	52	5	5	2	1	2	2	1	4	22	1	+7.2
23		11 02	589	477	16 32	112	19 01	21.3	07.1	06 21	14.2	16 10	908	974	20 44	66	3	3	4	3	3	2	4	2	24	1	+7.1
24		02 43	585	468	18 52	117	18 54	22.0	06.8	04 27	15.2	15 58	898	977	21 20	79	4	4	4	3	3	3	3	5	29	1	+6.9
25		23 59	592	481	16 50	111	16 21	19.5	03.4	01 59	16.1	16 43	907	967	00 12	60	5	2	4	3	3	4	3	3	27	1	+7.0
26		00 57	614	475	15 58	139	18 50	20.7	03.8	11 21	16.9	16 05	899	960	21 59	61	4	3	2	3	3	2	3	3	23	1	+7.1
27		01 55	563	479	16 10	104	18 27	20.0	05.3	00 41	14.7	16 13	894	960	00 05	66	4	2	3	3	2	2	3	3	22	1	+7.1
28	Q	01 31	587	487	17 14	100	18 16	20.9	05.1	03 21	15.8	17 15	897	951	21 48	54	3	4	2	2	2	3	3	3	22	1	+7.3
29	Q	00 32	588	488	16 30	100	18 24	19.5	04.0	13 47	15.5	16 40	897	948	00 37	51	4	3	1	2	2	1	2	2	17	1	+7.3
30		08 48	603	461	15 25	142	18 19	23.3	02.7	11 23	20.6	09 20	885	964	21 53	79	2	2	3	4	4	3	3	3	24	1	+7.3
31		05 26	593	476	15 34	117	18 52	20.3	04.6	13 22	15.7	06 10	894	954	22 09	60	3	4	4	3	4	2	2	3	25	1	+7.5

+ 16 00.0 + tabulated value.

N.B. On 29th

25 K' = 1 27 K' = 1

APRIL 1958

SENSITIVE MAGNETOGRAM INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Coeur
 All charts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to times as near from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
 Temperature Trace
 H Trace
 Baseline
 Temperature trace reflection,
 Baseline
 D Trace
 Baseline and Trace.
 Effective temperature coefficient:
 Baseline values increase with increasing temperature.
 Algebraic baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
 D Trace
 Baseline, H Trace, D Trace, Double
 Baseline
 F Trace
 H Trace
 D Trace
 Baseline

Clock correct to within 30 seconds throughout

Temperature trace
 Scale Value 0.527°C/mm
 Base Line -31.5°C
 Parallax correction + 4 minutes

Horizontal force trace
 Scale Value 4.43 Y/mm
 Base Line 1st to 16th 23483Y at 0°C
 17th to 30th 23482Y 16.1 Y/mm Actual
 24015Y

Temperature coefficient 4.50 Y/°C
 Parallax correction + 2 minutes
 Reflection distance:
 Main trace to 1st refl. down 89.6mm Nil

Declination trace
 Scale Value 0.92 minutes arc/mm
 Base Line Actual 17°39.6' 2.36 minutes arc/mm
 16°22.7'

Parallax correction + 2 minutes
 Reflection distance:
 Main trace to 1st refl. down - 1 minute

Vertical force trace
 Scale Value 2.50Y/mm
 Base Line 1st to 4th -36999Y at 0°C
 5th to 16th -37000Y " "
 17th to 30th -36879Y " " 10.9 Y/mm Actual
 -36823Y

Temperature coefficient 2.96 Y/°C
 Parallax correction Nil
 Reflection distances:
 Main trace to 1st refl. down 95.5mm
 Main trace to 1st refl. up 75.3mm - 2 minutes

Distance between base lines H to Z 155.8mm D to Z 181.7mm

Extreme values , daily ranges , and K-indices.

April 1958.

U.T. Date.	H			D			Z			K - indices.									C figure	Mean daily temp. of variometer room. C																	
	Maximum. 23000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. (36000+)	Minimum. (36000+)	Range.	1	2	3	4	5	6	7	8	Sum.																			
	h.m.	h.m.		h.m.	h.m.		h.m.	h.m.		h.m.	h.m.		h.m.	h.m.																							
1	07 10	582	487	15 41	95	17 58	19.2	02.9	02 25	16.3	07 54	914	961	20 40	47	4	3	3	2	2	5	4	3	24	1	+7.3											
2 D	10 46	600	484	15 52	116	17 51	19.0	03.3	06 41	15.7	07 07	861	954	00 10	73	2	3	5	4	3	3	2	3	25	1	+7.0											
3	02 42	581	476	16 13	105	18 19	19.5	59.9+	02 29	19.6	16 20	907	955	22 14	48	5	4	3	2	2	2	3	3	24	1	+7.1											
4 D	11 04	598	473	16 53	125	20 52	22.9	04.7	12 33	18.2	16 39	902	964	23 38	62	3	3	3	4	3	3	4	5	28	1	+7.1											
5	06 46	568	470	15 57	98	20 05	20.6	59.6+	02 30	21.0	03 02	890	968	01 20	76	5	4	3	3	3	3	2	2	25	1	+7.0											
6	05 38	583	480	15 51	93	17 51	19.5	05.5	01 10	14.0	16 30	906	959	00 48	53	5	3	4	4	2	2	3	4	27	1	+7.1											
7	11 03	573	486	16 04	97	18 20	20.3	05.9	04 51	14.4	08 28	908	954	22 10	48	3	3	3	3	3	1	2	2	20	1	+7.1											
8	09 52	572	476	16 04	94	19 11	17.5	06.6	13 44	10.9	16 05	908	949	22 06	41	3	3	1	2	1	1	1	3	15	1	+7.1											
9	10 22	574	499	16 03	75	22 19	17.7	06.6	13 21	11.1	15 35	912	945	00 01	33	2	3	1	1	1	1	1	3	13	0	+7.0											
10 Q	23 53	585	513	15 32	72	18 38	16.5	07.5	12 41	9.0	15 40	903	941	00 13	38	2	1	1	1	1	1	1	2	10	0	+7.0											
11 Q	00 42	599	509	15 33	90	17 39	15.9	07.3	13 11	8.6	14 37	904	938	00 48	34	2	2	1	2	1	1	1	3	13	0	+7.3											
12 Q	02 22	581	523	15 43	68	18 39	15.6	06.5	13 31	9.3	15 50	900	930	20 11	30	1	1	1	1	1	1	2	2	10	0	+7.1											
13 Q	02 03	595	532	15 14	63	18 27	15.4	06.7	13 23	8.7	15 17	898	927	23 39	29	2	1	1	1	1	0	1	1	8	0	+6.8											
14	11 13	598	519	23 59	79	19 20	19.0	04.6	13 30	14.4	15 12	892	942	23 51	50	2	2	2	3	3	2	3	3	20	1	+6.8											
15	07 29	587	496	00 29	91	20 15	16.7	01.0	03 42	15.7	03 54	874	953	00 18	79	5	5	4	3	3	2	3	5	30	1	+6.9											
16 D	11 30	615	504	23 07	111	22 44	20.0	03.7	02 32	16.3	07 18	879	953	23 09	74	4	3	4	4	4	2	3	5	29	1	+6.8											
17 D	09 18	583	442	15 35	141	18 30	18.8	58.8+	03 35	20.0	07 39	881	957	12 49	76	5	5	4	3	3	4	4	5	33	2	+6.9											
18 D	10 39	585	477	02 37	106	18 10	19.4	58.7+	03 09	20.7	09 01	875	963	23 06	88	5	5	4	4	4	2	3	5	32	2	+7.0											
19	10 46	575	474	16 05	101	19 25	18.3	06.8	01 44	11.5	09 55	889	953	23 07	64	3	3	2	4	2	2	4	4	24	1	+7.0											
20	03 15	584	497	15 41	87	18 10	17.0	04.5	21 51	12.5	06 23	894	945	00 11	51	3	4	3	2	2	2	1	4	21	1	+7.2											
21	11 25	577	499	15 55	78	18 49	17.2	05.3	03 19	11.8	16 00	901	936	00 02	35	2	3	3	2	2	2	2	4	20	1	+7.4											
22 Q	04 37	577	507	15 15	70	18 23	17.2	04.9	06 22	12.3	08 42	900	931	00 40	31	3	3	4	3	1	1	1	2	18	1	+7.3											
23	10 27	581	506	16 33	75	19 36	18.3	06.1	13 00	10.2	16 00	895	938	23 59	43	0	1	1	1	1	1	3	3	11	0	+7.4											
24	07 27	586	494	16 37	92	18 03	16.6	02.7	05 03	13.9	07 40	898	939	00 10	43	4	4	4	2	1	2	1	3	21	1	+7.4											
25	11 47	575	508	16 00	67	18 14	17.0	05.2	02 42	11.8	16 16	900	936	00 13	36	4	4	3	2	3	2	2	2	22	1	+7.2											
26	08 15	577	508	16 13	69	18 23	17.7	06.4	12 50	11.3	16 06	895	927	23 30	32	1	1	1	1	2	3	3	2	14	1	+7.2											
27	05 52	582	522	15 52	60	20 33	17.2	07.4	13 29	9.8	16 00	903	931	22 31	28	1	2	2	1	1	2	3	2	14	1	+7.2											
28	09 03	583	501	15 31	82	18 11	17.4	04.4	04 31	13.0	04 02	890	946	23 50	56	3	4	3	4	3	2	3	3	25	1	+7.1											
29	09 00	567	491	17 20	76	21 52	18.1	00.0	05 03	18.1	05 19	893	930	01 12	57	4	5	4	4	3	3	3	4	30	2	+7.0											
30	09 55	574	477	16 46	87	17 29	17.4	04.5	02 05	12.9	06 13	883	946	00 13	63	4	3	3	3	3	4	3	4	27	1	+6.6											

+ 16 00.0 + tabulated value.

SENSITIVE MAGNETOGRAM INSENSITIVE MAGNETOGRAM

Temperature trace		
Scale Value	0.527°C/mm	
Base Line	-31.5°C	
Parallax correction	+ 4 minutes	
Horizontal force trace		
Scale Value	4.43 Y/mm	16.1 Y/mm
Base Line	1st to 24th 23482Y at 0°C	24019Y Actual
	25th to 28th 23481Y " "	
	29th to 30th 23480Y " "	
	31st 23479 " "	
Temperature coefficient	4.50 Y/°C	—
Parallax correction	+ 2 minutes	Nil
Reflection distance:		
Main trace to 1st refl. down	89.6mm	
Declination trace		
Scale Value	0.92 minutes arc/mm	2.36 minutes arc/mm
Base Line Actual	17°39.6'	18°25.4'
Parallax correction	+ 2 minutes	- 1 minute
Reflection distance:		
Main trace to 1st refl. down		
Vertical force trace		
Scale Value	2.50 Y/mm	10.9 Y/mm
Base Line	1st to 2nd -36879Y at 0°C	-36825Y Actual
	3rd to 9th -36883Y " "	
	10th to 20th -36884Y " "	
	21st to 31st -36885Y " "	
Temperature coefficient	2.96 Y/°C	—
Parallax correction	Nil	- 2 minutes
Reflection distances:		
Main trace to 1st refl. up.	75.3mm	
Distance between base lines	H to Z 155.8mm	D to Z 181.8mm

Explanation

Instruments all standard La Cœur
 All charts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to times as read from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
 Temperature Trace
 H Trace
 .. Baseline
 (Temperature trace reflection)
 .. Baseline
 D Trace
 .. Baseline and Trace.
 Effective temperature coefficient:
 1. Baseline values increase with increasing temperature.
 2. Algebraic Baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
 D Trace
 D and line, H and line where double
 .. Baseline
 H Trace
 H Trace
 D Trace
 .. Baseline

clock correct to within 30 seconds throughout

Extreme values , daily ranges , and K-indices.

May 1958.

U.T.	H			D			Z			K - indices.	C figure	Mean daily temp. of variometer room.			
	Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. (-38000+)	Minimum. (-36000+)	Range.						
Date.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	h.m.	E 1 2 3 4 5 6 7 8	Sum.	C			
1	10 57	570	500 15 00	70	09 31	16.4 04.7 22 45	11.7	09 49	899	938 22 49	39	4 3 2 3 3 2 2 4	23	1	+6.4
2	06 03	572	498 16 10	74	19 32	15.8 03.7 07 20	12.1	07 38	895	950 00 50	35	4 4 4 2 1 2 2 3	22	1	+6.4
3	03 54	575	512 15 59	63	18 50	14.9 08.5 14 01	6.4	04 40	908	929 00 01	21	1 3 1 2 1 1 2 2	13	0	+4.1
4	08 33	583	516 16 46	67	18 56	13.8 05.7 00 18	8.1	08 02	898	927 23 40	29	4 3 3 2 1 1 1 3	18	1	+3.9
5	08 14	572	519 16 33	53	21 55	15.5 08.3 14 10	7.2	18 20	906	951 23 59	25	3 3 2 1 1 2 2 3	17	1	+4.1
6	04 36	570	506 15 32	64	18 44	14.6 06.4 05 35	8.2	17 08	904	951 00 04	27	3 3 3 1 1 1 1 2	15	1	+4.1
7	11 09	581	524 16 23	57	19 30	13.9 08.6 13 11	5.3	16 00	902	923 00 35	21	1 2 2 2 1 1 2 2	13	0	+4.2
8	02 36	587	519 22 37	68	22 11	15.4 06.7 13 11	8.7	15 45	897	921 23 49	24	2 3 2 2 2 2 2 4	19	1	+4.1
9	11 54	581	532 15 52	49	15 22	13.8 07.5 12 23	6.3	14 50	900	924 00 34	24	2 2 3 2 2 1 1 3	16	1	+4.1
10	11 15	584	517 23 14	67	23 10	17.5 01.8 07 51	15.7	08 10	885	923 21 38	38	3 3 4 3 2 2 3 4	24	1	+4.2
11	08 41	581	520 16 22	61	19 59	15.0 03.5 08 20	11.5	09 33	870	924 00 11	54	2 1 4 4 1 2 1 1	16	1	+4.2
12	08 55	577	513 23 19	64	22 30	18.4 08.9 13 59	9.5	20 50	900	951 23 59	31	1 1 2 1 2 2 3 4	16	1	+4.1
13	09 47	580	487 21 16	93	22 35	23.3 07.7 23 58	15.6	10 53	889	962 22 52	73	3 2 2 3 3 3 4 5	25	2	+4.1
14	07 23	582	444 00 57	118	19 02	16.6 34.5+ 01 06	22.1	03 36	887	955 00 15	48	5 4 5 3 3 3 3 3	31	2	+4.1
15	07 36	572	494 18 44	78	14 15	16.5 36.4+ 04 51	20.1	05 38	862	951 19 58	69	4 5 4 3 3 3 3 4	29	2	+4.3
16	09 13	558	503 16 14	55	09 59	14.8 04.1 01 19	10.7	09 38	894	929 00 44	35	4 3 3 3 2 2 2 2	21	1	+4.4
17	02 58	568	517 16 19	51	18 08	15.6 03.0 23 20	12.6	04 27	892	922 22 49	30	4 3 3 3 3 3 2 5	26	2	+4.4
18	10 44	593	511 17 44	82	18 00	15.6 05.1 01 17	10.5	10 24	889	923 01 23	34	4 4 3 4 2 2 2 3	24	1	+4.3
19	04 21	580	522 16 22	58	18 41	14.1 02.8 06 03	11.3	06 14	877	922 00 15	45	2 4 4 2 1 2 2 2	19	0	+4.3
20	10 40	568	533 15 56	35	18 40	13.7 08.6 00 53	5.1	18 03	907	913 00 02	8	2 2 1 2 2 1 2 2	14	0	+4.3
21	10 32	568	518 01 48	50	18 41	13.2 04.1 04 16	9.1	04 23	898	917 02 38	19	3 4 1 1 1 1 1 1	13	1	+4.5
22	10 27	574	541 15 14	33	17 42	12.6 08.9 13 21	3.7	14 41	902	913 20 12	11	1 1 1 1 1 1 1 1	8	0	+4.5
23	10 32	578	542 15 23	36	18 16	13.0 09.7 14 21	3.3	15 35	899	912 02 33	13	3 2 1 1 1 1 1 1	11	0	+4.6
24	01 52	578	548 16 01	30	18 02	12.9 08.9 13 09	4.0	16 18	893	907 19 51	14	0 1 1 1 1 0 0 0	4	0	+4.5
25	19 13	585	533 22 52	52	23 50	13.4 09.1 13 54	4.3	22 37	892	905 19 11	13	0 1 1 1 0 1 2 3	9	0	+4.5
26	11 41	579	497 17 27	82	22 06	15.6 04.4 03 18	11.2	14 30	890	924 23 38	34	4 4 3 3 3 4 2 3	26	2	+4.4
27	08 59	573	497 22 17	76	19 33	17.8 03.5 01 54	11.3	11 40	888	955 23 58	47	4 3 3 3 4 2 3 4	26	2	+4.3
28	06 40	554	496 00 51	58	00 46	15.6 01.4 02 53	14.2	07 58	891	941 00 40	50	5 4 3 2 2 2 3 3	24	2	+4.3
29	10 03	572	484 18 13	88	12 29	24.1 32.8+ 01 03	31.3	09 04	782	934 21 35	152	6 4 6 5 3 3 3 3	35	2	+4.4
30	10 17	551	499 04 10	52	17 45	14.3 06.4 04 13	7.9	08 55	901	930 00 13	29	2 4 3 3 2 1 2 4	21	1	+4.5
31	09 31	573	412 19 09	161	23 54	38.0 00.8 03 11	37.2	19 11	871	1051 23 46	180	4 4 3 4 3 4 5 6	33	2	+4.5

+ 16 00.0+ tabulated value.

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Coeur
 All charts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to times as read from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
 Temperature Trace
 H Trace
 Baseline
 (Temperature trace reflection,
 D Baseline
 D Trace
 Z Baseline and Trace.
 Effective temperature coefficient:
 1 Baseline values increase with increasing temperature.
 2 Algebraic Baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
 D Trace
 D Baseline, Up or line where double
 H Baseline
 T Trace
 H Trace
 Z Trace
 Baseline

Clock correct to within 30 seconds throughout

Temperature trace
 Scale Value
 Base Line
 Parallax correction

0.527°C/mm
 -31.5°C
 + 4 minutes

Horizontal force trace
 Scale Value
 Base Line

4.43 Y/mm
 1st 23478Y at 0°C
 2nd 23477Y " "
 3rd 23476Y " "
 4th 23475Y " "
 5th 23474Y " "
 6th 23473Y " "
 7th 23472Y " "
 8th 23471Y " "
 9th to 31st 23470Y " "

16.1 Y/mm
 24017Y Actual

Temperature coefficient
 Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

4.50 Y/°C
 + 2 minutes
 89.6mm

Nil

Declination trace
 Scale Value
 Base Line Actual

0.92 minutes arc/mm
 1st to 21st 17°39.6'
 22nd to 31st 17°39.0'

2.36 minutes arc/mm
 16°25.4'

Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace
 Scale Value
 Base Line

2.50 Y/mm
 1st to 12th -36886Y at 0°C
 13th to 24th -36887Y " "
 25th to 31st -36888Y " "

10.9 Y/mm
 -36826Y Actual

Temperature coefficient
 Parallax correction
 Reflection distances:
 Main trace to 1st refl. up
 Main trace to 1st refl. down

2.96 Y/°C
 Nil
 75.4mm
 95.6mm

- 2 minutes

Distance between base lines

H to Z 155.6

D to Z 1st, 7th and 8th
 181.8mm
 29th 178.8mm

Extreme values , daily ranges, and K-indices.

June 1958.

U.T.	h.m.	H			D			Z			K - indices.	C Figure	Mean daily temp. of variometer room. C													
		Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(36000+)	Minimum. -(36000+)	Range.																
Date.											B	1	2	3	4	5	6	7	8	Sum.						
1 D	23 59	528	578	01 15	150	00 01	34.4	49.6 ⁺	02 53	44.8	05 54	853	1085	00 52	252	7	6	5	3	2	2	3	5	33	2	+4.4
2	12 05	569	476	02 19	95	11 44	19.6	02.5	05 00	17.5	07 16	855	948	00 01	80	4	4	4	4	4	3	2	2	27	2	+4.4
3 Q	21 22	548	518	15 22	30	18 09	14.5	09.6	11 13	4.9	11 43	909	925	00 02	16	1	1	1	1	1	2	1	1	9	0	+4.2
4 Q	22 34	564	529	15 12	35	17 02	13.4	09.3	06 53	4.1	16 47	905	915	00 19	10	1	2	2	1	1	1	1	1	10	0	+5.9
5	23 58	569	532	16 32	37	18 05	13.2	07.7	07 51	5.5	16 22	897	914	21 13	17	1	1	2	1	1	2	1	1	10	0	+4.1
6	05 42	561	520	22 45	61	23 41	17.9	04.3	07 53	13.6	08 07	888	919	23 59	31	0	2	3	2	1	1	2	4	15	1	+4.0
7 D	01 59	605	564	02 30	259	01 54	17.1	42.6 ⁺	01 16	34.5	01 16	778	973	03 41	195	7	5	5	5	3	3	2	2	33	2	+3.3
8	21 56	553	487	23 50	66	23 21	14.1	04.7	23 57	9.4	23 58	900	922	00 01	22	1	1	1	1	2	2	2	4	14	1	+3.8
9	06 12	566	468	23 50	98	23 11	24.7	03.5	07 18	21.2	06 45	883	949	23 59	86	4	3	4	3	3	2	4	4	27	2	+4.3
10	11 45	548	424	01 38	124	00 11	22.4	53.7 ⁺	02 11	28.7	02 32	876	964	00 24	88	6	4	4	3	3	2	2	3	27	2	+4.5
11	12 08	567	496	01 49	71	11 43	14.5	05.1	05 29	9.4	03 59	888	926	03 26	38	3	4	3	3	3	2	2	3	23	1	+4.4
12	04 49	571	527	17 16	44	19 26	13.5	01.9	01 41	11.6	08 49	879	919	00 30	40	2	4	4	3	2	2	2	3	22	1	+4.4
13	04 54	568	531	01 43	37	18 03	12.6	06.1	00 16	6.5	05 08	885	911	00 01	25	3	3	3	1	1	2	2	2	17	1	+4.3
14	18 36	568	507	23 58	61	23 13	13.2	07.0	06 42	6.2	20 47	892	906	18 37	14	2	2	3	2	1	1	3	4	16	1	+4.3
15	05 34	576	507	04 50	69	10 11	14.0	56.7 ⁺	06 04	17.3	05 58	836	914	01 14	78	4	5	5	3	2	2	2	1	24	1	+4.4
16	06 33	565	525	16 11	40	17 56	15.2	04.5	07 25	8.7	07 25	875	907	19 56	32	3	2	4	3	3	2	1	1	10	1	+4.4
17 Q	04 22	567	537	00 39	30	17 01	12.0	06.5	04 52	5.5	05 01	892	907	19 40	15	2	3	2	1	1	1	1	1	12	0	+4.4
18 Q	12 53	570	527	22 07	43	22 02	13.3	08.5	13 11	4.8	15 20	890	904	23 58	14	2	1	1	1	1	2	2	3	13	0	+4.5
19	09 48	573	552	17 15	21	17 18	11.9	08.3	05 17	3.6	17 15	889	903	00 03	14	1	2	2	1	1	2	2	2	13	0	+4.3
20 Q	10 24	571	539	22 43	32	23 19	11.1	06.1	02 18	5.0	22 45	884	899	03 12	15	3	2	1	1	1	1	1	3	13	0	+4.3
21 D	11 23	616	459	21 19	157	11 21	32.8	52.3 ⁺	02 32	40.5	11 40	807	937	23 31	130	6	4	4	6	4	4	4	5	37	2	+4.3
22	00 11	566	481	00 39	85	22 56	14.9	48.5 ⁺	00 03	23.6	06 40	839	921	01 15	62	6	5	4	4	3	2	2	4	30	2	+4.4
23	12 20	552	504	00 53	48	17 33	12.3	04.3	02 31	8.0	05 12	869	917	00 02	48	4	3	3	2	2	2	2	2	20	1	+4.3
24	08 02	562	520	05 17	42	15 19	15.1	03.9	01 30	11.2	07 43	862	911	22 29	49	4	4	4	2	3	3	3	3	26	2	+4.3
25	10 37	566	520	04 40	46	19 00	13.5	03.1	03 23	10.4	08 44	877	911	02 00	34	3	4	2	3	2	2	3	2	21	1	+4.2
26	11 44	561	528	15 21	33	17 41	12.0	04.9	06 11	7.1	06 20	884	905	13 40	21	2	3	3	2	1	1	1	2	15	1	+4.2
27	11 53	565	525	22 50	40	23 26	13.2	07.7	06 44	5.5	22 40	889	903	03 07	14	2	2	3	2	1	1	1	3	15	1	+4.1
28 D	11 28	587	377	22 10	210	21 28	26.0	00.6	04 33	25.4	20 19	876	955	23 34	79	3	5	3	4	2	2	5	6	30	2	+4.3
29 D	13 10	534	561	00 56	173	05 20	26.2	42.9 ⁺	00 58	43.3	05 09	817	1021	00 57	204	7	6	5	5	3	4	3	2	37	2	+4.4
30	20 52	550	496	04 06	54	02 10	15.5	09.5	08 39	6.0	23 42	905	928	02 32	21	3	2	1	1	2	2	1	1	13	1	+4.4

+ 16 00.0 + tabulated value.

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Coeur
 All charts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to time as read from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
 Temperature Trace
 H Trace
 1 Baseline
 (Temperature trace reflection,
 1 Baseline
 J Trace
 2 Baseline and Trace.
 Effective temperature coefficient:
 1 Baseline values increase with increasing temperature.
 2 Algebraic Baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
 D Trace
 D Baseline, 1p or line where double
 1 Baseline
 F Trace
 L Trace
 G Trace
 2 Baseline

Clock correct to within 50 seconds throughout

Except 20th 2100L to 21st 1400L Time marking erratic up to 2 minutes in error.

Temperature trace
 Scale Value
 Base Line
 Parallax correction

0.527°C/mm
 -31.5°C
 + 4 minutes

Horizontal force trace
 Scale Value
 Base Line

4.43 Y/mm
 1st to 15th 23470Y at 0°C
 16th to 18th 23471Y " "
 19th to 21st 23472Y " "
 22nd to 25th 23473Y " "
 26th to 28th 23474Y " "
 29th to 31st 23475Y " "

16.1 Y/mm Actual

Temperature coefficient
 Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

4.50 Y/°C
 + 2 minutes

Nil

Declination trace
 Scale Value
 Base Line Actual

0.92 minutes arc/mm
 1st to 24th 17°39.0'
 25th to 31st 17°38.2'

2.36 minutes arc/mm

Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace
 Scale Value
 Base Line

2.50Y/mm
 1st to 5th -36888Y at 0°C
 6th to 13th -36889Y " "
 14th to 15th -36893Y " "
 16th to 18th -36894Y " "
 19th to 21st -36895Y " "
 22nd to 26th -36896Y " "
 27th to 30th -36897Y " "
 31st -36898Y " "

10.9 Y/mm Actual

Temperature coefficient
 Parallax correction
 Reflection distances:

2.96 Y/°C
 Nil

- 2 minutes

Distance between base lines

H to Z 155.6mm

D to Z 178.6mm

Extreme values , daily ranges , and K- indices.

July 1958.

U.T.	h.m.	H			D			Z			K - indices.								C figure	Mean daily temp. of variometer room. C							
		Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(36000+)	Minimum. -(36000+)	Range.	E	1	2	3	4	5	6	7			8	Sum.					
1	25 20	547	502	02 14	45	18 01	14.1	00.3	01 43	13.8	06 41	886	913	04 20	27	5	3	3	3	3	1	1	1	2	21	1	+4.5
2	20 02	554	529	15 23	25	23 13	14.0	07.3	09 55	6.7	10 07	893	906	23 30	13	1	1	1	2	1	1	1	1	2	10	0	+4.5
3	05 41	557	522	17 03	35	16 43	14.8	07.2	11 18	7.6	17 00	883	909	00 38	26	2	2	2	2	2	2	2	2	2	16	1	+4.6
4	08 42	535	514	17 35	51	18 06	15.2	01.4	09 01	13.8	09 09	850	913	23 28	53	1	2	4	4	3	3	2	3	22	1	+4.7	
5	02 37	570	525	22 59	47	22 50	14.9	06.6	07 46	8.1	14 28	888	912	00 10	24	3	2	2	2	2	2	1	4	18	1	+4.9	
6	00 45	562	528	02 43	34	17 51	12.6	06.8	03 01	5.8	14 38	891	906	00 43	15	3	3	1	1	1	1	1	0	11	0	+4.8	
7	11 45	583	539	15 12	44	17 50	12.2	06.7	11 04	5.5	11 10	880	898	21 45	18	1	2	2	3	2	2	2	3	17	1	+4.8	
8	08 02	682	275	17 19	407	10 49	46.9	45.0+	21 54	65.9	11 52	677	1306	21 50	629	3	2	6	7	7	7	7	8	47	2	+4.5	
9	22 34	511	519	07 54	192	00 30	34.4	01.3	08 47	33.1	08 09	838	1002	00 02	164	6	4	6	6	5	3	2	4	36	2	+4.6	
10	22 38	521	441	00 01	80	01 19	17.6	02.3	01 51	15.3	05 00	900	949	01 11	49	5	4	4	2	2	2	2	3	24	1	+4.6	
11	11 00	546	487	00 47	59	20 35	14.3	05.2	02 19	8.1	11 30	901	928	02 02	27	4	3	3	3	2	1	3	3	22	1	+4.4	
12	04 20	559	507	15 28	52	17 17	15.5	04.9	04 06	8.6	09 19	873	928	00 29	53	3	3	3	3	3	3	2	2	22	1	+4.4	
13	03 01	558	510	16 42	48	17 10	15.3	04.3	06 05	9.0	08 38	880	909	22 23	29	3	3	4	2	2	2	1	2	19	1	-1.2	
14	09 20	547	511	16 03	36	08 39	14.3	03.9	04 31	10.4	08 50	876	908	03 16	32	3	4	4	4	3	2	2	1	23	1	-2.0	
15	08 59	542	520	16 37	22	16 48	13.2	07.4	04 34	5.8	10 00	893	906	02 39	13	3	2	2	2	1	1	1	2	14	0	-1.9	
16	04 36	548	513	23 12	35	23 04	13.2	06.6	05 02	6.6	16 10	892	905	00 28	13	2	3	1	1	1	1	2	2	13	0	-1.5	
17	04 57	574	513	00 46	56	00 48	12.0	56.9+	05 29	15.1	05 34	869	910	01 00	41	4	5	4	3	1	1	1	1	20	1	-1.5	
18	07 52	581	497	23 06	84	12 19	14.3	00.1	06 58	14.2	07 55	857	909	23 59	72	4	3	5	4	3	3	3	4	29	2	-1.7	
19	07 36	591	472	22 54	119	21 20	14.5	01.4	08 32	13.1	08 11	849	908	00 34	59	3	3	4	3	2	2	4	5	26	2	-1.9	
20	08 11	552	480	02 43	72	12 52	14.2	00.6	05 46	13.6	05 43	861	908	04 20	47	4	4	3	3	3	3	2	3	25	2	-1.6	
21	20 52	571	491	16 39	80	19 00	20.7	05.9	16 38	14.8	18 53	877	921	19 31	44	3	3	3	2	2	4	5	4	26	2	-1.9	
22	04 44	557	518	12 15	39	00 01	12.5	05.9	01 39	6.6	12 17	884	905	02 24	21	4	3	2	3	3	2	2	2	21	1	-1.6	
23	11 27	551	522	16 53	29	18 21	12.2	08.3	23 48	3.9	15 09	888	900	20 04	12	1	1	1	1	1	1	1	2	9	0	-1.4	
24	12 22	558	514	02 31	44	18 12	15.6	05.8	02 01	9.8	17 45	877	900	22 48	23	3	2	1	2	2	3	3	2	18	1	-1.5	
25	11 18	556	493	22 42	63	21 53	13.9	59.7+	08 11	14.2	09 40	864	905	20 12	41	1	1	4	5	3	2	3	4	23	1	-1.1	
26	07 45	545	496	00 00	49	18 00	12.5	01.3	02 32	11.2	09 35	885	907	00 06	22	5	3	3	2	2	1	2	2	20	1	-1.0	
27	07 10	553	477	23 05	76	21 43	18.3	59.5+	07 28	19.3	07 48	824	920	23 57	96	3	4	4	4	4	3	3	4	29	2	-0.5	
28	20 39	556	476	02 02	80	18 09	13.0	01.3	01 39	11.7	05 40	888	923	00 11	35	4	3	3	0	0	0	2	2	14	1	+0.5	
29	23 51	555	510	16 23	45	18 31	13.4	08.0	13 38	5.4	15 00	884	902	20 15	18	2	1	0	1	1	1	3	2	11	0	-1.1	
30	06 54	561	514	16 30	47	20 49	12.7	04.6	07 18	8.1	07 27	877	901	23 30	24	2	2	3	2	1	1	2	3	16	1	-1.5	
31	11 24	549	492	17 22	57	17 27	16.0	02.5	07 00	13.5	17 21	868	900	21 27	32	2	2	3	3	1	4	2	1	18	1	-2.1	

+ 16 00.0 + tabulated value.

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Cœur
 All charts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to time as read from the magnetogram.

Sensitive Magnetogram

Order of Traces (from top to bottom),
 Temperature Trace
 H Trace
 .. Baseline
 (Temperature trace reflection)
 F Baseline
 D Trace
 C Baseline and Trace.
 Effective temperature coefficient:
 1. Baseline values increase with increasing temperature.
 2. Algebraic Baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces (from top to bottom),
 D Trace
 D Baseline, 1p or line where double
 .. Baseline
 F Trace
 H Trace
 C Trace
 .. Baseline

Block correct to within 30 seconds throughout

Except 9th 0000Z to 1500Z Time marking erratic see aided hour marks

Temperature trace
 Scale Value
 Base Line
 Parallax correction

0.527°C/mm
 -31.5°C
 + 4 minutes

Horizontal force trace
 Scale Value
 Base Line

4.43 Y/mm
 1st to 3rd 25476Y at 0°C
 4th to 5th 25477Y " "
 7th to 9th 25478Y " "
 10th to 31st 25479Y " "

16.1 Y/mm Actual

Temperature coefficient
 Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

4.50 Y/°C
 + 2 minutes
 89.7mm

Nil

Declination trace
 Scale Value
 Base Line Actual

0.92 minutes arc/mm
 17°38.2'

2.36 minutes arc/mm

Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace
 Scale Value
 Base Line

2.50Y/mm
 1st to 2nd -36898Y at 0°C
 3rd to 5th -36899Y " "
 6th to 9th -36900Y " "
 10th to 31st -36901Y " "

10.9 Y/mm Actual

Temperature coefficient
 Parallax correction
 Reflection distances:
 Main trace to 1st refl. down
 Main trace to 1st refl. up

2.96 Y/°C
 Nil
 95.6mm
 75.3mm

- 2 minutes

Distance between base lines

H to Z 155.7mm

D to Z 178.6mm

Extreme values , daily ranges , and K-indices.

August 1958.

U.T.	E			D			Z			K - indices.									C Figure	Mean daily temp. of variometer room. C						
	Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(36000+)	Minimum. -(36000+)	Range.	1	2	3	4	5	6	7	8	Sum.								
Date.	h.m.	h.m.		h.m.	h.m.		h.m.	h.m.		1	2	3	4	5	6	7	8									
1	11 17	556	511	16 03	45	17 01	13.0	07.7	13 39	5.3	11 30	875	896	02 09	21	2	2	1	3	3	2	2	2	17	1	-2.1
2	23 59	556	507	16 40	49	17 02	14.0	06.1	05 33	7.9	16 18	877	900	19 48	23	2	3	2	2	2	3	2	2	18	1	-1.9
3	02 03	560	517	16 17	43	18 31	13.4	02.2	01 43	11.2	05 18	863	898	00 01	55	4	4	4	3	3	2	1	1	22	1	-2.1
4 Q	03 29	553	526	17 20	27	17 50	13.1	07.5	05 27	5.6	16 11	874	894	20 40	20	1	2	2	1	1	1	1	1	10	0	-2.4
5 Q	02 26	556	523	14 23	33	18 13	12.6	07.0	07 55	5.6	16 44	869	889	02 27	20	1	1	2	2	2	1	1	1	11	0	-2.2
6 Q	08 10	556	519	15 22	37	18 31	11.6	07.7	13 42	3.9	14 54	875	890	00 15	15	1	1	1	1	1	1	1	2	9	0	-2.1
7	10 52	569	511	15 49	58	18 01	13.5	06.7	03 30	6.6	15 33	869	889	22 00	20	2	2	2	3	3	2	2	1	17	1	-2.3
8 Q	10 55	558	516	15 28	42	17 45	12.3	06.6	13 39	5.9	16 32	874	888	23 22	14	1	1	1	1	1	1	1	1	8	0	-2.2
9	11 14	560	523	15 53	37	18 15	11.6	03.1	03 58	9.5	16 12	869	888	01 21	19	3	3	1	1	1	1	1	2	13	0	-2.2
10	06 38	575	519	15 40	56	19 26	14.5	01.4	07 21	13.1	07 32	865	892	21 53	27	2	2	4	3	1	2	3	3	20	1	-2.3
11	03 16	575	505	15 40	70	18 59	13.5	01.5	05 43	12.0	10 30	853	889	01 21	36	3	3	5	3	2	1	2	1	20	1	-2.9
12	22 03	567	522	16 30	45	18 32	12.3	03.2	06 22	9.1	06 08	859	887	00 33	28	2	3	3	2	2	1	2	2	17	1	-2.1
13	04 59	561	505	15 07	56	18 17	12.3	56.9 [†]	06 38	15.4	06 27	835	890	21 10	55	2	3	5	3	1	2	1	2	19	1	-1.9
14	11 02	563	517	14 23	46	13 47	14.0	05.1	02 51	8.9	18 43	869	898	23 59	29	3	3	1	1	1	1	2	3	15	1	-1.8
15	04 29	577	517	00 12	60	17 21	12.1	01.9	04 43	10.2	04 41	863	896	00 59	33	3	4	1	1	1	1	1	1	13	1	-1.7
16	10 39	558	506	02 03	50	18 32	13.4	06.3	13 38	7.1	15 45	863	887	04 22	24	4	3	2	1	1	2	2	2	17	1	-1.6
17 D	06 29	629	438	22 40	191	22 25	22.2	01.9	13 11	20.3	09 23	829	951	23 39	122	2	2	5	4	4	5	5	5	32	2	-1.6
18 D	04 17	538	465	00 05	73	18 11	13.4	00.4	05 33	13.0	05 29	833	921	00 55	88	4	5	3	2	2	1	1	2	20	1	-2.1
19	11 22	549	495	16 04	54	18 30	13.7	05.2	02 20	8.5	15 49	869	899	00 59	30	3	3	2	2	2	2	2	2	18	1	-1.4
20 Q	07 42	554	500	15 23	54	17 51	13.1	06.6	13 03	6.5	15 34	868	892	21 10	24	2	2	2	1	1	1	1	1	11	0	-1.1
21	11 50	560	508	15 35	52	18 23	13.8	06.8	12 45	7.0	15 39	861	894	22 06	33	2	1	0	2	2	1	1	3	12	0	-1.1
22 D	02 31	521	492	06 31	129	18 00	14.3	50.5 [†]	04 03	23.8	06 29	746	911	02 31	165	3	5	6	2	2	2	3	2	28	2	-1.0
23	06 02	564	499	16 14	65	19 28	13.4	05.6	06 22	9.8	16 15	862	895	22 48	31	2	4	3	1	1	2	2	2	17	1	-1.9
24 D	02 21	630	410	03 27	220	12 00	24.0	41.7 [†]	02 21	42.3	04 54	587	908	01 44	219	6	6	5	6	5	3	3	2	36	2	-1.9
25	00 22	543	485	16 19	58	19 01	15.8	01.5	05 09	14.3	06 34	873	901	00 28	28	3	4	3	2	4	2	2	2	22	1	-1.8
26	11 03	558	484	16 12	74	19 00	15.2	03.3	06 27	11.9	11 00	839	901	23 52	62	3	4	3	4	3	2	2	3	24	1	-1.9
27 D	03 20	567	452	09 12	115	18 10	19.5	52.7 [†]	05 45	26.8	07 45	749	908	23 10	159	3	5	5	6	4	3	4	4	34	2	-1.7
28	09 58	543	482	17 10	61	19 00	18.3	07.8	05 39	10.7	14 45	862	908	23 03	46	2	3	3	3	3	2	3	2	21	1	-2.0
29	09 57	560	480	16 09	80	18 00	15.8	06.0	12 51	9.8	16 12	855	901	00 01	46	1	2	2	2	2	2	2	3	16	1	-1.4
30	09 09	559	496	15 47	63	18 12	16.6	04.8	13 19	11.8	15 29	855	897	00 40	42	3	2	2	2	2	2	1	2	16	1	-1.9
31	09 25	563	490	16 42	73	18 30	16.6	06.2	12 17	10.4	16 39	846	888	00 48	42	2	2	2	2	1	2	2	1	14	0	-2.6

[†] 16 00.0 + tabulated value.

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Coker
 All starts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to time as read from the magnetogram.

Sensitive Magnetogram

Order of Traces from top to bottom,
 Temperature Trace
 H Trace
 Baseline
 Temperature trace reflection,
 Baseline
 J Trace
 Baseline and Trace.
 Effective temperature coefficient:
 Baseline values increase with increasing temperature.
 Algebraic baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces from top to bottom,
 D Trace
 Baseline, D trace reflection double
 Baseline
 J Trace
 H Trace
 J Trace
 Baseline

Clock correct to within 30 seconds throughout

Temperature trace
 Scale Value
 Base Line
 Parallax correction

0.527°C/mm
 -31.5°C
 + 4 minutes

Horizontal force trace
 Scale Value
 Base Line

4.43 Y/mm
 1st to 20th 25479Y at 0°C
 21st to 30th 3478Y " "

16.1 Y/mm
 Actual

Temperature coefficient
 Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

4.50 Y/°C
 + 2 minutes
 89.6mm

Nil

Declination trace
 Scale Value
 Base Line Actual

0.92 minutes arc/mm
 17°38.2'

2.56 minutes arc/mm

Parallax correction
 Reflection distance:
 Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace
 Scale Value
 Base Line

2.50Y/mm
 1st to 19th -36901Y at 0°C
 20th to 30th -36897Y " "

10.9 Y/mm
 -36848Y Actual

Temperature coefficient
 Parallax correction
 Reflection distances:
 Main trace to 1st refl. down
 Main trace to 1st refl. up

2.96 Y/°C
 Nil
 95.6mm
 75.3mm

- 2 minutes

Distance between base lines

H to Z 155.8mm

D to Z 178.1mm

Extreme values , daily ranges , and K-indices.

September 1958.

Date.	U.T.	H			D			Z			K - indices.	C figure	Mean daily temp. of variometer room. C								
		Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(56000+)	Minimum. -(56000+)	Range.											
		h.m.	h.m.		h.m.	h.m.		h.m.	h.m.		E 1 2 3 4 5 6 7 8 Sum.										
1		10 44	563	492	15 44	71	18 58	15.1	04.4	13 17	10.7	15 30	851	886	21 30	35	1 1 1 2	2 1 1 2	11	0	-2.3
2		10 43	561	495	16 02	66	18 30	15.2	06.5	13 21	8.7	15 50	853	885	01 05	32	1 1 1 1	1 1 1 2	9	0	-2.3
3	D	09 22	526	428	22 54	168	21 31	20.8	01.5	12 31	19.3	10 12	814	915	22 56	101	2 2 3 5	5 4 4 6	31	2	-2.2
4	D	05 09	540	252	23 11	288	22 29	41.1	57.4+	23 00	43.7	15 35	791	1143	22 59	352	5 4 3 3	5 5 6 7	38	2	-2.0
5	D	22 31	500	268	01 20	232	03 31	25.0	51.6+	04 41	33.4	04 28	760	1056	00 53	296	7 7 3 3	3 3 4 2	32	2	-2.1
6		23 57	525	456	16 02	69	19 10	16.8	03.0	14 01	8.8	16 07	879	920	00 12	41	1 2 1 2	1 2 2 2	13	0	-1.7
7		05 58	551	454	15 22	97	22 50	25.5	05.1	14 08	18.4	15 29	856	930	23 58	74	2 3 3 3	2 2 3 5	23	1	-1.8
8		22 18	552	477	16 02	75	18 40	15.9	02.5	02 29	13.4	15 50	870	930	00 01	60	4 4 1 1	1 2 2 4	19	1	-2.1
9		06 12	563	477	15 18	88	18 21	18.1	03.2	13 49	14.9	13 51	862	907	22 39	45	4 3 3 3	3 2 3 4	25	1	-1.1
10		11 09	553	469	16 54	84	18 20	17.6	04.3	01 47	13.5	16 49	858	903	00 12	44	3 3 2 2	2 2 2 3	19	1	-1.8
11		07 39	567	482	15 47	85	18 16	16.8	04.3	13 39	12.5	16 00	853	894	01 31	41	3 2 2 2	2 2 2 2	17	0	-1.8
12		11 03	562	490	16 23	72	18 31	16.0	04.9	13 30	11.1	16 20	849	890	00 01	41	2 2 1 1	1 1 1 1	10	0	-1.7
13	↓	10 36	560	488	15 58	72	18 35	15.7	04.3	13 18	11.4	16 31	850	888	20 53	38	1 1 0 0	0 0 1 1	4	0	-1.6
14	↓	10 31	567	502	15 33	65	19 18	15.4	03.2	13 12	12.2	16 10	843	882	00 40	39	1 1 1 1	1 0 1 2	8	0	-1.2
15		04 42	571	505	15 20	66	18 08	15.4	02.2	13 21	13.2	16 26	840	880	01 20	40	1 1 1 1	1 2 2 1	10	0	-1.5
16	D	04 05	585	472	21 30	113	17 50	18.7	58.6+	04 32	20.1	18 26	837	900	23 38	63	3 4 4 4	4 4 4 4	31	1	-2.1
17		05 37	549	470	15 22	79	18 03	16.9	02.9	00 43	14.0	15 25	850	901	00 13	51	4 3 2 2	2 2 2 1	18	1	-2.3
18	↓	09 15	549	488	15 40	63	19 39	16.4	04.2	13 31	12.2	15 40	853	887	21 53	34	1 0 2 1	1 1 2 2	10	0	-2.3
19		10 15	564	487	15 45	77	19 21	15.9	03.1	12 05	12.8	15 47	848	886	00 00	38	1 1 1 2	2 1 2 2	12	0	+2.1
20		02 20	564	501	15 52	63	18 36	15.3	03.4	13 11	11.9	16 30	841	882	21 38	41	2 2 1 1	1 1 1 1	10	0	+2.3
21	↓	10 08	568	503	16 48	65	19 03	15.6	04.1	12 47	11.5	16 40	838	878	00 20	40	1 0 1 1	1 1 2 1	8	0	+2.4
22	↓	10 36	569	500	15 30	69	18 39	15.5	04.1	13 30	11.4	16 10	830	873	00 01	43	1 1 1 1	1 1 1 1	8	0	+2.6
23		02 49	570	502	15 32	68	18 44	16.1	04.1	12 09	12.0	16 40	830	877	21 22	47	2 1 1 1	1 0 1 3	10	0	+2.4
24		02 58	573	496	14 49	77	18 54	15.9	05.4	13 01	12.5	17 00	837	879	23 03	42	3 1 2 1	1 1 2 4	15	1	+2.7
25	D	04 21	631	403	22 59	227	18 21	25.9	48.9+	08 04	37.0	07 01	734	945	22 25	211	3 6 5 5	4 4 3 6	36	2	+2.6
26		23 03	537	456	15 00	81	18 52	19.6	03.3	08 34	16.3	08 39	855	916	00 09	61	5 4 4 4	3 2 2 3	27	1	+2.9
27		04 07	541	465	15 33	76	19 08	16.4	05.9	13 45	10.5	15 36	853	895	00 26	42	2 3 3 2	2 3 2 3	20	1	+3.0
28		01 53	551	476	15 41	75	19 02	16.1	04.8	08 51	11.3	16 30	850	892	01 00	42	3 3 2 3	2 1 1 2	17	1	+3.2
29		05 52	559	492	16 14	67	19 02	15.5	05.0	13 00	10.5	16 40	843	880	00 38	37	2 2 2 1	1 1 1 2	12	0	+3.1
30		11 18	576	482	16 30	94	19 05	19.7	01.9	12 22	17.8	16 32	828	904	21 31	76	1 1 2 3	3 2 3 4	19	1	+2.6

+ 16 00.0 + tabulated value.

OCTOBER 1958

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Cœur
 All charts complete Greenwich days except for charts showing only part days.
 Parallax correction to be added to time as read from the magnetogram.

Sensitive Magnetogram

Order of Traces (from top to bottom),
 Temperature Trace
 H Trace
 Baseline
 Temperature trace reflection/
 Baseline
 D Trace
 Baseline and Trace.
 Effective temperature coefficient:
 1. Baseline values increase with increasing temperature.
 2. Algebraic baseline values decrease with increasing temperature.

Insensitive Magnetogram

Order of Traces (from top to bottom),
 D Trace
 Baseline, H Trace, D Trace, double
 Baseline
 D Trace
 H Trace
 D Trace
 Baseline

Clock correct to within 30 seconds throughout

Temperature trace				
Scale Value	0.527°C/mm			
Base Line	-31.5°C			
Parallax correction	+ 4 minutes			
Horizontal force trace				
Scale Value	4.43 Y/mm		16.1 Y/mm	
Base Line	1st to 28th 23478Y at 0°C			Actual
	29th to 31st 23477Y " "			
Temperature coefficient	4.50 Y/°C		---	
Parallax correction	+ 2 minutes		Nil	
Reflection distance:				
Main trace to 1st refl. down	89.6mm			
Declination trace				
Scale Value	0.92 minutes arc/mm		2.36 minutes arc/mm	
Base Line Actual	17°38.2'			
Parallax correction	+ 2 minutes		- 1 minute	
Reflection distance:				
Main trace to 1st refl. down				
Vertical force trace				
Scale Value	2.50 Y/mm		10.9 Y/mm	
Base Line	-36897Y at 0°C			Actual
Temperature coefficient	2.96 Y/°C		---	
Parallax correction	Nil		- 2 minutes	
Reflection distances:				
Main trace to 1st refl. down	95.7mm			
Distance between base lines	H to Z 155.9mm		D to Z 178.5mm	

Extreme values , daily ranges , and K-indices.

October 1958.

U.T.	h.m.	H			D			Z			K - indices.								C	C figure	Mean daily temp. of variometer room. C					
		Maximum. 23000+	Minimum. 23000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(56000+)	Minimum. -(58000+)	Range.	Σ	1	2	3	4	5	6	7				8	Sum.			
1	03 48	588	474	15 15	114	19 25	17.0	02.0	06 44	15.0	16 02	842	895	22 33	51	3	4	4	1	1	1	3	4	21	1	+5.0
2	02 30	556	477	15 38	79	18 21	16.1	03.1	05 59	13.0	07 29	849	892	02 22	43	4	3	4	1	1	2	1	3	19	1	+5.0
3	04 59	565	466	15 46	99	18 23	22.6	01.3	05 22	21.3	16 21	825	884	21 35	59	3	3	4	3	3	3	5	2	24	1	+5.0
4	23 40	576	475	15 31	101	18 11	17.6	03.0	12 59	14.6	15 39	834	888	23 40	54	2	2	2	1	2	1	2	3	15	0	+2.8
5	07 02	574	479	15 30	95	17 40	18.3	05.0	11 33	13.3	16 00	836	887	21 39	51	3	2	3	2	2	3	2	3	20	1	+5.0
6	04 33	590	485	15 29	105	17 41	18.8	02.4	13 11	16.4	15 31	851	892	21 51	61	2	3	1	1	3	2	3	3	18	1	+5.2
7	05 38	579	473	16 47	106	18 49	20.3	06.1	05 51	14.2	16 45	828	891	21 14	63	3	3	3	2	2	3	3	4	23	1	+5.3
8	06 43	554	489	15 44	65	16 01	17.2	03.8	03 40	13.4	15 53	840	882	00 09	42	3	4	3	2	2	1	1	2	18	1	+5.1
9	02 37	567	479	15 03	88	18 03	17.1	05.0	13 11	12.1	16 00	828	874	20 58	46	3	3	1	1	1	1	2	2	14	0	+2.8
10	02 28	573	487	16 03	86	17 43	17.2	03.8	12 31	13.4	15 54	825	870	23 59	45	2	1	0	1	1	2	2	1	10	0	+5.2
11	02 27	570	499	15 38	71	19 22	16.2	04.6	12 01	11.6	16 29	826	873	22 40	47	2	1	1	1	1	1	2	3	12	0	+5.3
12	02 18	569	499	15 42	70	19 31	15.8	04.2	12 51	11.6	16 13	831	884	23 14	33	1	0	0	0	1	1	2	2	7	0	+5.2
13	03 22	579	489	15 43	90	19 23	16.3	03.6	10 57	12.7	16 30	815	863	23 23	48	1	2	2	2	2	2	3	2	16	1	+5.4
14	04 29	583	497	16 09	86	19 15	17.5	04.2	14 00	13.3	16 13	828	857	21 46	39	2	3	1	2	3	2	1	3	17	1	+5.2
15	04 33	573	499	15 26	79	19 02	17.9	04.5	10 49	13.4	16 20	819	872	23 00	53	2	2	2	2	2	2	3	2	17	1	+5.3
16	04 11	582	491	16 12	91	19 00	15.0	04.3	13 18	10.7	06 01	817	866	22 42	49	2	3	3	1	2	1	2	1	15	1	+5.3
17	04 12	588	491	16 31	97	19 38	17.2	04.1	10 52	13.1	16 55	819	869	21 42	50	3	3	2	2	1	3	2	3	19	1	+5.1
18	01 43	576	481	15 35	95	18 23	15.1	02.6	13 27	12.5	16 08	817	869	22 23	52	2	2	2	2	1	2	2	2	15	1	+5.1
19	03 02	574	473	16 20	101	18 18	19.6	02.0	11 25	17.6	16 41	801	872	22 07	71	2	2	1	3	1	2	2	3	16	1	+5.0
20	21 32	582	472	15 19	110	18 56	19.8	03.7	12 10	16.1	17 11	809	877	21 40	68	3	1	1	1	1	2	3	4	16	1	+5.2
21	02 17	590	483	15 59	107	17 54	17.9	04.4	10 02	13.5	16 10	813	867	23 50	54	3	3	1	2	1	2	3	2	17	1	+5.2
22	03 20	628	457	16 35	171	19 32	23.0	56.7 ⁺	06 53	26.3	08 12	780	924	22 04	144	2	5	6	5	3	3	4	4	32	2	+5.1
23	23 36	560	413	14 14	147	17 39	23.9	56.0 ⁺	06 15	27.9	08 57	802	941	21 50	139	4	4	5	5	4	3	3	4	32	2	+5.0
24	07 32	565	352	13 20	213	17 24	29.3	50.5 ⁺	08 18	38.8	10 09	710	964	22 35	254	4	4	6	6	5	5	4	5	39	2	+2.8
25	23 59	532	435	15 02	97	18 37	18.5	07.7	06 56	10.8	15 49	847	927	00 02	80	4	3	3	2	1	1	2	2	18	1	+5.5
26	03 33	558	461	13 57	97	17 31	18.6	02.7	08 44	15.9	08 50	839	886	22 01	47	2	3	3	3	2	2	2	2	19	1	+5.8
27	02 12	555	473	14 18	82	18 45	28.7	05.7	10 26	23.0	15 01	827	942	21 16	115	2	3	2	2	1	3	5	4	22	1	+3.5
28	07 46	562	442	15 32	120	18 04	23.1	02.2	07 59	20.9	12 41	815	922	22 15	107	3	2	4	4	4	3	3	4	27	2	+3.0
29	23 43	571	430	15 44	141	18 52	17.9	04.1	09 32	13.8	16 01	823	916	23 41	93	3	3	3	3	2	3	4	4	25	1	+5.3
30	21 47	558	447	15 02	111	17 40	18.9	02.3	10 21	16.6	14 29	823	903	21 48	80	3	2	3	3	3	2	4	4	24	1	+5.1
31	22 23	574	436	16 19	138	18 19	17.9	01.3	10 11	16.6	16 20	810	882	00 14	72	3	3	3	3	2	4	3	3	24	1	+5.3

⁺ 16 00.0 + tabulated value.

SENSITIVE MAGNETOGRAM INSENSITIVE MAGNETOGRAM
NONE INCLUDED

Explanation

Instruments all standard La Coeur
All charts complete Greenwich days except for charts showing only part days.
Parallax correction to be added to time as read from the magnetogram.

Temperature trace
Scale Value
Base Line
Parallax correction

0.527°C/mm
-31.5°C
+ 4 minutes

Horizontal force trace
Scale Value
Base Line

4.43 Y/mm
1st to 12th 23477Y at 0°C
13th to 26th 23476Y " "
27th to 30th 23475Y " "

16.1 Y/mm Actual

Sensitive Magnetogram

Order of Traces from top to bottom,
Temperature Trace
H Trace
Baseline
Temperature trace reflection,
Baseline
D Trace
Baseline and Trace.
Effective temperature coefficient:
1. Baseline values increase with increasing temperature.
2. Algebraic baseline values decrease with increasing temperature.

Temperature coefficient
Parallax correction
Reflection distance:
Main trace to 1st refl. down

4.50 Y/°C
+ 2 minutes
89.6mm

Nil

Insensitive Magnetogram

Order of Traces from top to bottom,
D Trace
Baseline, if or line where double
Baseline
H Trace
H Trace
D Trace
Baseline

Declination trace

Scale Value
Base Line Actual

0.92 minutes arc/mm
17°38.2'

2.36 minutes arc/mm

Parallax correction
Reflection distance:
Main trace to 1st refl. down

+ 2 minutes

- 1 minute

Vertical force trace

Scale Value
Base Line

2.50 Y/mm
1st to 11th -36898Y at 0°C
12th to 24th -36899Y " "
25th to 31st -36897Y " "

10.9 Y/mm Actual

Clock correct to within 30 seconds throughout

Temperature coefficient
Parallax correction
Reflection distances:

2.96 Y/°C
Nil

- 2 minutes

Distance between base lines

H to Z 155.9mm

D to Z

Extreme values , daily ranges , and K-indices.

November 1958.

U.T.	h.m.	H			D			Z			K - indices.								C figure	Mean daily temp. of variometer room. C							
		Maximum. 23000+	Minimum. 23000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(36000+)	Minimum. -(36000+)	Range.	E	1	2	3	4	5	6	7			8	Sum.					
1		02 22	582	479	14 49	103	18 25	19.3	01.8	11 10	17.5	15 18	810	874	00 17	64	2	2	2	3	2	2	3	2	18	1	+4.0
2	D	01 35	590	481	18 23	99	17 30	20.8	02.3	11 29	18.3	15 16	811	887	23 26	76	2	0	2	2	2	4	3	3	18	1	+4.6
3	D	03 30	584	468	14 05	96	19 09	16.0	02.5	11 37	13.5	14 17	834	887	00 58	53	2	3	3	3	3	2	3	3	22	1	+4.9
4		03 23	566	484	14 44	82	18 23	15.2	59.8 ⁺	12 01	15.4	13 17	831	878	00 11	47	2	3	2	4	4	2	3	3	23	1	+4.4
5		02 02	567	494	15 16	73	17 43	15.3	04.7	10 31	10.6	13 47	824	885	02 01	41	2	1	1	1	1	1	1	1	9	0	+3.8
6	Q	05 43	566	507	13 59	59	18 04	15.1	04.3	00 42	10.8	15 18	826	859	00 55	33	1	1	1	1	1	1	1	2	9	0	+4.3
7		03 02	577	507	15 58	70	18 09	15.8	04.5	08 48	11.5	14 40	822	873	21 26	51	2	1	2	2	2	2	2	2	15	1	+5.1
8	Q	22 23	568	493	15 02	75	18 28	14.5	04.0	09 29	10.5	16 11	820	862	00 00	42	1	2	1	2	1	1	2	1	11	0	+6.7
9		23 50	585	516	15 14	69	18 12	13.4	02.5	09 41	10.9	15 12	812	830	01 43	49	1	3	1	1	1	0	2	2	11	0	+6.8
10	D	04 04	595	484	14 35	111	17 41	16.6	57.5 ⁺	09 12	19.1	13 59	793	870	23 48	77	1	3	3	5	3	2	4	3	24	2	+6.2
11	D	01 33	606	471	13 29	135	17 01	18.0	58.7 ⁺	06 42	19.3	05 47	810	884	01 35	74	4	4	4	3	3	2	2	2	24	2	+5.3
12		04 05	578	462	14 20	114	17 41	16.1	02.3	11 57	13.8	14 08	808	869	21 53	61	2	2	2	3	3	2	3	3	20	1	+4.3
13		01 29	573	462	14 02	111	17 40	17.2	03.6	10 57	13.6	14 24	817	867	00 54	50	3	3	2	2	2	2	1	17	1	+3.4	
14		22 12	576	483	15 35	93	17 41	15.9	03.5	10 36	12.4	14 48	803	866	22 11	63	2	1	2	2	1	1	1	3	13	0	+3.4
15		06 17	582	486	14 32	96	18 32	14.4	03.1	08 31	11.3	13 14	816	859	23 51	43	3	2	3	1	2	0	1	2	14	1	+3.7
16		02 28	609	503	14 43	106	18 00	12.9	59.7 ⁺	10 11	13.2	12 49	804	867	00 31	63	3	4	2	3	3	2	2	3	22	1	+3.5
17		23 59	581	491	15 13	90	17 54	14.5	01.4	07 11	13.1	15 31	804	860	23 59	56	2	2	3	3	1	2	3	2	18	1	+3.8
18		21 02	576	511	14 52	65	18 33	18.4	04.0	11 10	14.4	14 34	802	874	21 13	72	1	2	3	2	2	2	3	3	18	1	+3.4
19		02 47	574	500	14 30	74	18 08	16.3	03.5	11 01	12.8	14 18	806	855	00 25	49	2	1	2	2	1	2	1	1	12	0	+3.2
20		23 59	568	496	15 15	72	17 32	15.7	01.9	11 07	13.2	15 39	799	849	02 48	50	2	1	1	2	1	2	1	1	11	0	+3.0
21		23 12	579	503	15 46	76	18 11	15.1	01.7	11 04	13.4	15 20	800	857	23 13	57	1	1	1	2	1	1	2	2	11	0	+3.4
22	Q	00 35	593	496	16 06	97	18 20	14.2	02.3	10 13	11.9	15 15	806	861	00 36	55	3	2	2	2	2	1	1	2	15	1	+3.3
23		03 43	591	514	14 59	77	17 01	16.3	59.3 ⁺	10 30	17.0	13 05	794	851	00 48	57	2	2	2	3	4	3	2	3	21	1	+3.1
24		01 36	569	481	15 30	88	17 56	20.3	00.3	09 25	20.0	15 25	784	859	21 22	75	1	1	2	3	3	3	3	3	19	1	+3.1
25		02 46	593	483	15 50	110	18 21	21.5	00.4	10 18	21.1	15 50	791	885	23 40	94	3	2	2	2	3	3	3	3	21	1	+6.3
26		03 30	565	473	14 22	92	17 01	19.0	01.4	10 31	17.6	13 39	805	878	00 01	73	3	3	2	2	2	3	2	3	20	1	+7.0
27		03 03	575	476	15 16	99	18 31	19.9	02.5	10 33	17.4	14 17	804	881	23 50	77	2	3	2	2	2	2	2	2	17	1	+7.0
28	D	01 19	596	455	15 48	141	17 20	18.4	57.5 ⁺	08 57	20.9	14 32	788	878	01 20	90	3	3	4	4	4	3	3	3	27	2	+7.3
29		01 16	587	458	15 47	129	19 01	18.1	01.2	11 37	16.9	15 14	802	863	23 16	61	3	3	3	3	3	2	2	3	22	1	+7.3
30	Q	05 17	573	469	15 01	104	17 51	18.4	02.5	11 20	15.9	15 10	800	858	20 15	58	2	2	1	1	1	1	2	1	11	0	+7.3

⁺ 16 00.0+ tabulated value.

SENSITIVE MAGNETOGRAM

INSENSITIVE MAGNETOGRAM

Explanation

Instruments all standard La Cœur
 All charts complete observation days except for charts showing only part days.
 Parallax correction is based on time of day and from the magnetogram.

Sensitive Magnetogram

Temperature trace
 Scale Value 0.527°C/mm
 Base Line -31.5°C
 Parallax correction + 4 minutes

Horizontal force trace
 Scale Value 4.43 Y/mm
 Base Line 1st to 7th 23475Y at 0°C
 7th to 31st 23474Y " "

Temperature coefficient 4.50 Y/°C
 Parallax correction + 2 minutes
 Reflection distance:
 Main trace to 1st refl. down 89.6mm

Order of Traces from top to bottom,
 Temperature Trace
 H Trace
 Baseline
 Temperature trace reflection,
 Baseline
 D Trace
 Baseline and Trace.
 Effective temperature coefficient:
 1. Baseline values increase with increasing temperature.
 2. Algebraic baseline values decrease with increasing temperature.

Inensitive Magnetogram

Declination trace
 Scale Value 0.92 minutes arc/mm
 Base Line Actual 17°38.2'

Parallax correction + 2 minutes
 Reflection distance:
 Main trace to 1st refl. down - 1 minute

Vertical force trace
 Scale Value 2.50 Y/mm
 Base Line 1st to 19th -36895Y at 0°C
 20th to 26th -36896Y " "
 27th to 31st -36897Y " "

Order of Traces from top to bottom,
 D trace
 Baseline, H trace where double
 Baseline
 D Trace
 H Trace
 D Trace
 Baseline

Block correct to within 30 seconds throughout

Temperature coefficient 2.96 Y/°C
 Parallax correction Nil
 Reflection distances:
 Main trace to 1st refl. down 85.6mm
 Main trace to 1st refl. up 75.3mm

Distance between base lines H to Z 155.9mm D to Z 178.0mm

Extreme values , daily ranges , and K - indices.

December 1958.

Date.	U.T.	H			D			Z			K - indices.								C figure	Mean daily temp. of variometer room. C																				
		Maximum. 25000+	Minimum. 25000+	Range.	Maximum. 17 00.0+	Minimum. 17 00.0+	Range.	Maximum. -(36000+)	Minimum. -(36000+)	Range.	E	1	2	3	4	5	6	7			8	Sum.																		
		h.m.	h.m.		h.m.	h.m.		h.m.	h.m.		h.m.	h.m.																												
1	Q	05 10	579	486	14 52	93	17 41	16.9	01.7	10 36	15.2	14 50	798	850	03 00	52	2	1	1	2	2	2	2	2	14	0	+9.2													
2		21 52	622	481	13 18	141	17 41	21.5	57.4 ⁺	10 04	24.1	13 20	791	832	21 55	141	2	3	3	5	3	3	4	5	28	1	+9.6													
3		01 33	588	462	13 57	128	17 26	18.1	02.3	10 31	15.8	14 25	801	875	01 20	74	3	2	1	2	2	2	2	16	0	+9.9														
4	D	00 40	629	420	15 50	209	18 41	25.6	49.3 ⁺	09 38	39.3	10 23	764	1034	22 48	270	5	3	4	6	5	4	6	6	39	2	+10.3													
5	D	23 47	547	433	16 05	114	18 01	21.0	05.1	01 05	15.9	16 08	826	957	00 01	131	5	3	3	3	3	2	3	3	25	1	+10.5													
6		23 35	561	469	15 33	92	18 21	19.2	04.7	10 00	14.5	13 39	812	880	22 34	68	3	2	2	3	3	2	3	3	21	1	+10.1													
7	Q	04 17	568	481	15 13	87	17 41	16.9	04.1	11 27	12.8	15 30	805	871	00 51	66	2	2	3	2	2	2	2	17	0	+9.9														
8		23 14	596	484	14 12	112	19 11	17.1	03.3	11 13	13.8	14 00	808	892	23 12	84	2	2	2	2	3	2	4	4	21	1	+9.7													
9		01 03	587	498	14 40	89	17 33	17.2	02.6	08 53	14.6	07 59	797	874	01 02	77	3	3	4	2	1	3	2	2	20	1	+9.8													
10	Q	08 02	570	482	14 58	88	17 11	15.8	03.6	10 10	12.2	15 57	805	858	00 28	53	2	2	3	2	1	2	1	2	13	0	+10.1													
11		21 45	577	476	14 48	99	18 15	21.4	02.6	09 52	18.8	16 02	791	859	22 04	68	3	2	3	3	3	2	3	3	22	1	+10.4													
12	Q	21 05	594	477	13 02	117	18 14	17.7	02.7	09 56	15.0	13 02	788	867	21 12	79	3	2	2	3	4	3	3	4	24	1	+10.5													
13	D	00 08	649	439	13 52	210	18 40	25.5	54.6 ⁺	12 41	30.9	13 48	773	922	21 32	149	5	3	3	4	5	4	4	5	33	2	+10.2													
14		03 05	536	444	14 15	152	18 48	22.7	01.0	11 08	21.7	14 26	798	895	00 02	97	4	4	2	2	4	3	4	4	27	1	+10.2													
15		21 24	594	464	14 10	130	16 14	17.6	01.3	09 44	16.3	13 40	792	864	00 01	72	3	2	1	2	3	3	4	4	22	1	+10.5													
16		02 10	656	484	16 36	172	18 36	14.3	57.6 ⁺	11 38	16.7	12 38	784	869	02 14	85	5	4	2	4	4	2	4	3	28	1	+10.0													
17	D	18 22	672	473	22 23	194	18 22	31.5	03.2	07 50	28.3	14 00	795	935	23 56	140	3	3	2	3	1	4	6	6	28	2	+10.0													
18	D	02 11	597	473	15 55	124	02 51	16.3	01.4	10 08	14.9	13 10	824	935	00 01	111	5	4	2	3	3	2	2	4	25	1	+10.0													
19		00 56	567	457	13 45	110	17 55	17.5	01.4	08 50	16.1	13 06	808	889	00 58	81	4	4	3	4	3	2	3	3	26	1	+9.9													
20		00 40	585	460	15 44	125	17 20	19.6	00.8	06 58	18.8	16 39	800	875	00 40	75	3	2	3	3	2	2	3	3	21	1	+9.9													
21		23 59	577	478	15 07	99	18 11	19.0	02.2	10 23	16.8	14 40	804	861	21 40	57	2	2	3	3	2	3	3	3	21	1	+10.1													
22		00 14	586	473	13 23	108	18 31	16.1	00.8	09 06	15.3	13 26	798	863	00 18	65	4	1	2	3	3	2	3	3	21	1	+10.1													
23		21 22	571	476	14 04	95	18 02	17.8	58.7 ⁺	09 37	19.1	14 10	782	863	21 35	81	2	2	4	3	2	3	3	3	22	1	+9.7													
24		21 59	576	479	16 09	97	17 08	17.0	01.3	12 04	15.7	15 47	788	854	22 00	66	2	2	2	2	2	1	2	3	16	0	+9.7													
25	Q	23 35	625	493	14 42	132	16 50	16.6	02.3	09 51	14.3	12 36	792	857	23 46	65	1	1	1	1	1	1	3	5	14	1	+9.9													
26		00 02	617	498	16 12	119	18 04	20.3	01.6	09 37	18.7	15 50	787	871	21 37	64	4	3	2	2	3	3	4	4	25	1	+10.2													
27		23 37	591	475	15 02	116	17 51	18.9	03.7	05 51	15.2	16 17	782	871	23 40	89	3	3	3	3	4	3	1	3	23	1	+10.5													
28		20 31	585	470	15 24	115	18 31	17.2	59.7 ⁺	09 35	17.5	15 19	782	872	23 10	90	3	3	3	3	3	3	4	3	25	1	+10.2													
29		01 01	572	492	14 15	80	18 01	18.7	01.5	11 54	17.2	15 50	788	870	21 59	84	3	2	2	2	2	3	3	4	21	1	+10.1													
30		22 36	597	495	15 52	102	17 56	20.4	00.6	11 22	19.8	15 51	779	866	22 38	87	2	2	2	2	3	3	3	4	21	1	+9.8													
31		00 27	579	492	14 44	87	17 20	17.8	01.7	12 01	16.1	15 34	780	849	00 28	69	2	2	2	1	2	2	3	2	16	0	+9.8													

⁺ 16 00.0 + tabulated value.

N.B.
On 11th, 17 K' = 3
12th, E5 K' = 2
31st, E6 K' = 1